

the Energy to Lead

High-Efficiency Heating Rooftop Units (RTUs) – The Final Frontier for Condensing Gas Furnaces

Douglas Kosar
Senior Institute Engineer
Gas Technology Institute

CenterPoint Energy
Energy Efficiency and Technology Conference
May 21, 2014

Presenter

- > Douglas Kosar
Senior Institute Engineer
Gas Technology Institute
- > 30+ years experience introducing new technologies to buildings
- > Last 5 years working to introduce condensing heating RTUs through
 - product R&D w/manufacturers
 - national account/other end user pilots
 - Consortium for Energy Efficiency (EE) & utility EE Program deployments



Source: GTI

Presentation Goals

- > Recognize the diversity in a given commercial building of individual RTU heating runtime/gas use
- > Apply higher efficiency heating RTUs in the most cost effective commercial building applications
- > Review the latest pilot project issues and results
- > Understand handling of RTU combustion condensate, especially in cold climates
- > Recognize other commercial heating product categories with emerging condensing options

Presentation Agenda –

35 minute presentation/10 minute Q&A

- > Individual RTU heating runtimes on a building
- > Initial ventilation markets for condensing heating
 - Dedicated Outside Air Systems (DOAS), for example
- > Condensing DOAS pilot in big-box retail stores
 - Net operating energy and cost savings, w/fan penalty
 - Added neutralizer maintenance cost, if code required
 - Condensing heating equipment cost premiums
 - Combustion condensate system installation and costs
 - Combustion condensate management practices
- > More condensing heating products in our future

Setting the Stage for Condensing RTUs

- > High efficiency, condensing heating RTUs are entering the commercial marketplace, BUT ...
- > Lack of non-condensing RTU heating load data on which to base savings & paybacks for condensing
 - Conflicting DOE & ASHRAE building modeling results
 - No RTU by RTU datasets for given building types
- > So monitoring undertaken of 107 RTUs/11 buildings
 - Current switch/logger timestamps gas valve runtime, nameplate rating provides gas use
 - 1 small office, 3 restaurants, 3 drug stores, 3 clothing & home goods stores, & 1 “big box” retail store

GTI Baseline Monitoring in the Field of Non-Condensing RTUs

- > 1 small office
- > 3 quick service restaurants
- > 3 drug/convenience stores
- > 3 clothing/home goods stores
- > 1 retail “super” store



Source: GTI

Heating Runtime & Gas Use Diversity

- > Perimeter RTUs w/longer runtimes while core RTUs w/shorter runtimes (in general, excess core RTU capacity increases w/area of building)
- > HI heat sees limited use – can benefit from 2 stage fan to reduce fan energy penalty in LO heat

Perimeter RTUs (1, 2, 3, & 5)
Core RTUs (4 & 6)

SMALL
OFFICE


Source: GTI



Usage Pattern & Excess Capacity

- > Entry, stock, & drive-thru RTUs see high use pattern that is repeated across “identical” stores
- > One “identical” store halved its installed heating capacity and had no HI heat use increase

**DRUG
STORE**



Source: GTI

Dedicated Outside Air System (DOAS)

- > Condition 100% OA for building ventilation
- > DOAS in retail stores (open 24/7) exhibit highest heating loads & longest runtimes for RTUs
- > Focus of follow-on condensing RTU demo

**“BIG BOX”
RETAIL
STORE**

Source: GTI



Key Takeaways So Far

- > Very diverse heating runtimes for RTUs on a given building, but patterns emerge
 - Perimeter zone RTUs see longer runtimes and interior zone RTUs see shorter runtimes
 - RTU layouts in “identical” buildings show consistency in RTU runtime patterns with opportunity for selective higher efficiency heating upgrades for high runtime RTUs
- > DOAS (or other high ventilation/make-up air fraction RTUs) exhibit highest heating/gas loads and present the most promising early market entry point for condensing RTUs

Condensing Heating DOAS Pilots in Big Box Retail Stores in IL and MN

> Nicor Gas ETP

- Baseline Winter 2010/2011 tests at IL store led to DOAS focus
- Condensing DOAS tests Winter 2012/2013 with annual savings of ~2400 therms per DOAS

> GTI NA ETP Collaborative

- Condensing DOAS tests began 3/2013 at MN store and continue through Winter 2013/2014
- Projected annual therm savings are similar but smaller due to differences in control schemes




Source: GTI



Pilot Project Installations

- > 3 step condensing heating module retrofit process
early Oct 2012 (Nicor Gas ETP)/Mar 2013 (NA ETP)
 1. Installation of condensate piping with neutralizer
 2. Replacement of non-condensing heating modules
 3. Completion of data acquisition system



Source: GTI

Combustion Condensate System – *from DOAS ...*

- > Plumbing slope minimum between condensate ports of heating module
- > Then vertical drop thru RTU base to conditioned space
- > Trap inside the conditioned space before run to sanitary drain



To heat tape
or
not to heat tape ...
that is the question!

Ensure heating module
design avoids standing
condensate and
maintains water tight
gasket connections!



Source: GTI

Combustion Condensate System – ... to Sanitary Drain

- > Long runs to code required sanitary drain disposal
- > Acidic condensate neutralization is limited local code issue presently
 - > Well established neutralizers from condensing boilers
 - > Annual/2 year maintenance



Take advantage of roof deck plumbing slope for condensate line!



Replenish neutralizer calcium carbonate when outlet pH drops below 5.5!

Source: GTI

DOAS Heating Module Retrofit


> Two (2) DOAS with two (2) heating modules each



Source: GTI

Condensing Heating Module



- > RTUs fundamentally scale up residential condensing furnace heat exchangers, but
 - RTUs supply fans may run continuously during HVAC operating schedule and incremental pressure drop can create significant year round fan energy penalty
 - Condensate management must consider freezing rooftop environments



Source: Modine

MN Store Pilot Issues this Winter


- > Condensate leakage
- > Flue icing buildup
- > Burner flame rollout fault
- > Supply fan kWh increase (slipping belt replacement)



Source: GTI

Condensate Leakage

- > Combustion fan gasket leakage detected & DOAS shutdown 12/16-18/13
- > Gasket replaced 1/13/14 and no further leakage has been detected since
- > Even w/OA temperatures below design conditions drain line has not frozen even though no external heat applied to PVC pipes



Source: GTI

Icing at Flues is Typical in Operation

Residential Condensing
Furnace Flue in MN



Big Box Retail Store Condensing
DOAS Flues in MN



Source: GTI

DOAS Operating Cost Savings

– MN Store 7/23/13 – 3/31/14

Per **RAW** data, gas savings 1800 therms (11%) with 940 kWh added fan electricity for net energy savings of \$1084 @ \$0.65/therm gas & \$0.08/kWh electricity

Condensing Heating RTU Retrofit of DOAS (Munters HCU) at Target Store, Medina, MN										input cells	update cell range		
Cumulative										Gas Usage Decrease Cumulative	Electricity Cumulative	Net Savings Cumulative	
Usage Date		through	HDD	Gas Heat Cumulative	therms	Supply Fan Electricity Cumulative	kWh	therms	\$	kWh	\$	\$	
7/23/2013		3/31/2014	7925	1419804	14397	8812		1800	1163.26	940	78.76	1084.50	
Daily										Gas Usage Decrease	Electricity Increase @ cfm of	Net Savings	
Reading Date	Reading Time	Usage Date	KMIC Crystal	Gas Heat Daily	@ 1014 Btu/ft^3	Supply Fan Electricity Daily	Fan Runtime Daily	80%	to Condensing TE	90%	Electricity Increase @ ΔP of	Net Savings	
MM/DD/YYYY	HH:MM:SS	MM/DD/YYYY	HDD65	ft3	therms	kWh	0.00 to 1.00		therms	\$/therm	inch WG	\$/kWh	
									\$		\$/kWh	\$	
3/25/2014	0:00:00	3/24/2014		43.0	7733	78.41	45.58	1.00	9.80	\$6.34	4.23	\$0.35	\$5.98
3/26/2014	0:00:00	3/25/2014		47.9	8015	81.27	46.28	1.00	10.16	\$6.57	4.23	\$0.35	\$6.21
3/27/2014	0:00:00	3/26/2014		37.9	7334	74.37	45.54	1.00	9.30	\$6.01	4.23	\$0.35	\$5.65
3/28/2014	0:00:00	3/27/2014		28.9	6159	62.45	42.94	1.00	7.81	\$5.05	4.23	\$0.35	\$4.69
3/29/2014	0:00:00	3/28/2014		33.9	7111	72.11	44.82	1.00	9.01	\$5.83	4.23	\$0.35	\$5.47
3/30/2014	0:00:00	3/29/2014		32.7	7129	72.29	44.72	1.00	9.04	\$5.84	4.23	\$0.35	\$5.49
3/31/2014	0:00:00	3/30/2014		17.9	3180	32.25	43.82	1.00	4.03	\$2.61	4.23	\$0.35	\$2.25
4/1/2014	0:00:00	3/31/2014		16.4	3222	32.67	43.47	1.00	4.08	\$2.64	4.23	\$0.35	\$2.29

Source: GTI

DOAS Net Operating Cost Savings – for IL Store Annually

Gas savings 2400 therms (11%) with 1285 kWh of added fan electricity for an annual net energy savings of \$1444 @ \$0.65/therm gas and \$0.09/kWh electricity

High Efficiency DOAS Net Operating Cost Savings																							
Assumptions	inputs	Net Annual Energy Cost Savings											positive	negative									
													Electricity (\$/kWh)										
Heating Module													0.05	0.06	0.07	0.08	0.09	0.10	0.11	0.12	0.13	0.14	0.15
Capacity Btu/hr Out	640,000	187.6 kw																					
Base AFUE/TE	80%		Gas Cost	0.50	1,135.74	1,122.89	1,110.04	1,097.18	1,084.33	1,071.48	1,058.63	1,045.77	1,032.92	1,020.07	1,007.22								
Base Btu/hr In	800,000	234.5 kw	(\$/therm)	0.55	1,255.74	1,242.89	1,230.04	1,217.18	1,204.33	1,191.48	1,178.63	1,165.77	1,152.92	1,140.07	1,127.22								
High Efficiency AFUE/TE	90%		X	0.60	1,375.74	1,362.89	1,350.04	1,337.18	1,324.33	1,311.48	1,298.63	1,285.77	1,272.92	1,260.07	1,247.22								
High Efficiency Btu/hr In	711,111	208.4 kw	9.479	0.65	1,495.74	1,482.89	1,470.04	1,457.18	1,444.33	1,431.48	1,418.63	1,405.77	1,392.92	1,380.07	1,367.22								
Heating Full Load Operating Hours/Yr	2700		(\$/GJ)	0.70	1,615.74	1,602.89	1,590.04	1,577.18	1,564.33	1,551.48	1,538.63	1,525.77	1,512.92	1,500.07	1,487.22								
				0.75	1,735.74	1,722.89	1,710.04	1,697.18	1,684.33	1,671.48	1,658.63	1,645.77	1,632.92	1,620.07	1,607.22								
Base therms/yr	21,600	2278.8 GJ/yr		0.80	1,855.74	1,842.89	1,830.04	1,817.18	1,804.33	1,791.48	1,778.63	1,765.77	1,752.92	1,740.07	1,727.22								
High Efficiency therms/yr	19,200	2026 GJ/yr		0.85	1,975.74	1,962.89	1,950.04	1,937.18	1,924.33	1,911.48	1,898.63	1,885.77	1,872.92	1,860.07	1,847.22								
Site Gas Savings therms/yr	2,400	253 GJ/yr		0.90	2,095.74	2,082.89	2,070.04	2,057.18	2,044.33	2,031.48	2,018.63	2,005.77	1,992.92	1,980.07	1,967.22								
Source Savings MMBtu/yr	245	258 GJ/yr		0.95	2,215.74	2,202.89	2,190.04	2,177.18	2,164.33	2,151.48	2,138.63	2,125.77	2,112.92	2,100.07	2,087.22								
		(x 1.02 site to source)		1.00	2,335.74	2,322.89	2,310.04	2,297.18	2,284.33	2,271.48	2,258.63	2,245.77	2,232.92	2,220.07	2,207.22								
				1.05	2,455.74	2,442.89	2,430.04	2,417.18	2,404.33	2,391.48	2,378.63	2,365.77	2,352.92	2,340.07	2,327.22								
				1.10	2,575.74	2,562.89	2,550.04	2,537.18	2,524.33	2,511.48	2,498.63	2,485.77	2,472.92	2,460.07	2,447.22								
Fan CFM	5000	2360 L/s		1.15	2,695.74	2,682.89	2,670.04	2,657.18	2,644.33	2,631.48	2,618.63	2,605.77	2,592.92	2,580.07	2,567.22								
Added Fan Δ P inch WG	0.15	37.35 Pa		1.20	2,815.74	2,802.89	2,790.04	2,777.18	2,764.33	2,751.48	2,738.63	2,725.77	2,712.92	2,700.07	2,687.22								
Fan&Motor Efficiency	0.6			1.25	2,935.74	2,922.89	2,910.04	2,897.18	2,884.33	2,871.48	2,858.63	2,845.77	2,832.92	2,820.07	2,807.22								
Added kW	0.15			1.30	3,055.74	3,042.89	3,030.04	3,017.18	3,004.33	2,991.48	2,978.63	2,965.77	2,952.92	2,940.07	2,927.22								
Fan Operating Hours/Yr	8760			1.35	3,175.74	3,162.89	3,150.04	3,137.18	3,124.33	3,111.48	3,098.63	3,085.77	3,072.92	3,060.07	3,047.22								
				1.40	3,295.74	3,282.89	3,270.04	3,257.18	3,244.33	3,231.48	3,218.63	3,205.77	3,192.92	3,180.07	3,167.22								
Site Added Fan kWh/yr	1285			1.45	3,415.74	3,402.89	3,390.04	3,377.18	3,364.33	3,351.48	3,338.63	3,325.77	3,312.92	3,300.07	3,287.22								
Source Added MMBtu/yr	14	15 GJ/yr		1.50	3,535.74	3,522.89	3,510.04	3,497.18	3,484.33	3,471.48	3,458.63	3,445.77	3,432.92	3,420.07	3,407.22								
		(x 3.16 site to source)																					

Source: GTI

DOAS Payback Economics – for IL Store

Based on installed cost premium of \$6085 for condensing DOAS and condensate system, plus a projected annual neutralizer maintenance cost of \$65 for calcium carbonate replenishment, a simple payback of 4.4 years is estimated

High Efficiency Heating Module DOAS Paybacks													
Assumptions		Payback in Years											
Condensing Heating Module and Condensate Piping and Neutralizer		Electricity (\$/kWh)											
		Gas Cost (\$/therm)	0.05	0.06	0.07	0.08	0.09	0.10	0.11	0.12	0.13	0.14	0.15
New Construction Installed Equipment Cost	\$ 6,069	0.50	5.7	5.7	5.8	5.9	6.0	6.0	6.1	6.2	6.3	6.4	6.4
		0.55	5.1	5.2	5.2	5.3	5.3	5.4	5.4	5.5	5.6	5.6	5.7
		0.60	4.6	4.7	4.7	4.8	4.8	4.9	4.9	5.0	5.0	5.1	5.1
Annual Neutralizer Maintenance Cost	\$ 65	0.65	4.2	4.3	4.3	4.4	4.4	4.4	4.5	4.5	4.6	4.6	4.7
		0.70	3.9	3.9	4.0	4.0	4.0	4.1	4.1	4.2	4.2	4.2	4.3
		0.75	3.6	3.7	3.7	3.7	3.7	3.8	3.8	3.8	3.9	3.9	3.9
		0.80	3.4	3.4	3.4	3.5	3.5	3.5	3.5	3.6	3.6	3.6	3.7
		0.85	3.2	3.2	3.2	3.2	3.3	3.3	3.3	3.3	3.4	3.4	3.4
		0.90	3.0	3.0	3.0	3.0	3.1	3.1	3.1	3.1	3.1	3.2	3.2
		0.95	2.8	2.8	2.9	2.9	2.9	2.9	2.9	2.9	3.0	3.0	3.0
		1.00	2.7	2.7	2.7	2.7	2.7	2.8	2.8	2.8	2.8	2.8	2.8
		1.05	2.5	2.6	2.6	2.6	2.6	2.6	2.6	2.6	2.7	2.7	2.7
		1.10	2.4	2.4	2.4	2.5	2.5	2.5	2.5	2.5	2.5	2.5	2.5
		1.15	2.3	2.3	2.3	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.4
		1.20	2.2	2.2	2.2	2.2	2.2	2.3	2.3	2.3	2.3	2.3	2.3
		1.25	2.1	2.1	2.1	2.1	2.2	2.2	2.2	2.2	2.2	2.2	2.2
		1.30	2.0	2.0	2.0	2.1	2.1	2.1	2.1	2.1	2.1	2.1	2.1
		1.35	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0	2.0
		1.40	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	1.9	2.0
		1.45	1.8	1.8	1.8	1.8	1.8	1.8	1.9	1.9	1.9	1.9	1.9
		1.50	1.7	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8	1.8

More Key Takeaways

- > Higher RTU runtimes key to generating high net operating cost savings for high efficiency payback
- > DOAS provides best early market payback scenario
 - “big box” retail accounts with established DOAS vendors
 - high heating degree day (HDD)/heating load locations
- > Mainstream condensing RTU transition hinges on
 - Progressing incremental pressure drop below 0.15”WG
 - Broadening RTU use of staged blowers
 - Achieving consensus on building heating loads

Condensing RTU Market Situation

- > Non-major, second tier HVAC companies introducing product lines and provide early market entry point
 - Dedicated outside air systems (DOAS)
 - Applied by some key “big box” retail accounts
- > Major HVAC companies on the sidelines for now, but introducing staged blowers that are improving their general outlook on condensing RTU economics
- > GTI baseline/pilot testing supports targeting DOAS ... but other technologies competing for OA roles
 - Direct fired vs. indirect fired condensing heating
 - Demand control ventilation (DCV)
 - Energy recovery ventilation (ERV)

Current Active Manufacturers

Manufacturer	Availability	Heating Module Specifications w/Hot Link (subject to change)
Engineered Air	now	90%TE, 100 – 1,400 MBH input, 15:1 turndown, 1,000 to 44,000 CFM www.engineeredair.com/index.php/our_products/category/indirect-fired#djx-series (DJX Series products)
Modine	now	90%TE, up to 500 MBH input, 7:1 turndown, up to 12,000 CFM www.modinehvac.com/web/Commercial-HVAC/Commercial-Ventilation-1.htm (Atherion products)
Reznor	now	up to 93% TE, up to 600 MBH package (400MBH split), up to 10:1 from 500 to 11,500 cfm package (6000 cfm split). www.rezspec.com/en/me/all-products (YDMA, YDHA, & YDSA products)
Munters	now	90%TE, up to 800 MBH input, 10:1 turndown, up to 16,000 CFM www.munters.us/en/us/Products--Services/Dehumidification/Energy-Recovery/Packaged-Energy-Recovery1/?Product=87392AFD-C031-4BC7-AED9-65E508651504 (DryCool product literature does not currently show condensing option)

Source: GTI

What the Future Holds

...

> Condensing heating RTUs


- challenging market development from 100 to 30% OA
 - > with current high equipment cost premiums
 - > and low natural gas prices in US/Canada
- logical market development will see progression in cost effectiveness to lower %OA RTUs over time
- $\leq 30\%$ OA will need to be competitive w/low-cost, mass-produced, non-condensing efficiency RTUs

> Other commercial (including multi-family) heating products are also going condensing heating

- even with sustained, lower natural gas prices
- steady increase in product categories $\geq 90\%$ AFUE/TE

... Expanding Condensing RTU Offerings

- > One manufacturer responding to the lower OA% challenge by providing condensing heating RTU product lines for the full (100 to 0) %OA spectrum
 - YDMA (~100 to 60% nominally)
 - YDHA (~60 to 30% nominally)
 - YDSA (~30 to 0% nominally)



The diagram shows three Reznor rooftop units labeled YDSA, YDHA, and YDMA. Each unit has red and blue arrows indicating air flow. The units are mounted on a building labeled 'PLATFORM 125'.

The complete line of Reznor rooftop units can provide comfort for a wide variety of conditions. Select the one right for your specific application.

- ▶ YDSA - Space Conditioning
- ▶ YDHA - High Outside Air Volume
- ▶ YDMA - Dedicated Outdoor Air

Source: Reznor

... Other Condensing Product Offerings

> Duct furnaces

- stand-alone or
- furnace for RTU



Source: Heatco

> Unit heaters

- Manufacturing, warehousing, automotive, retail buildings



Source: Modine

> Wall furnaces/hearths

- multifamily (rentals), home additions



Source: Empire

> Thru-the-wall furnace/AC

- multifamily (condos), senior living facilities

Source: Suburban



Bibliography

- > Kosar, Douglas, et al. 2014. Field Monitoring of Rooftop Unit (RTU) Heating Runtimes and Gas Usage for Selected Commercial Buildings (NY-14-C084). *ASHRAE Papers CD: 2014 ASHRAE Winter Conference*. Atlanta: ASHRAE.
- > Kosar, Douglas, et al. 2013. 1001: High Efficiency Heating Rooftop Units (RTUs) Public Project Report. Nicor Gas Emerging Technology Program. www.nicorgasrebates.com/emerging.
- > **Look for upcoming *ASHRAE Journal* article on condensing DOAS field test**

Sponsor Acknowledgements

> Utilization Technology Development (UTD)

www.utd-co.org

> Nicor Gas Emerging Technology Program

www.nicorgasrebates.com/emerging

> GTI North American Emerging Technology Program Collaborative

<http://www.gastechnology.org/Expertise/Pages/Emerging-Technology-Program.aspx>

and CenterPoint Energy, Union Gas, DTE Energy for their support

Contact Information

Douglas Kosar
Senior Institute Engineer
Building Energy Efficiency
Gas Technology Institute
1700 S. Mount Prospect Road
Des Plaines, IL 60018-1804
Office Phone: 847/768-0725
Office Fax: 847/768-0916
Cell Phone: 847/312-1398
E-mail: douglas.kosar@gastechnology.org
Web Site: www.gastechnology.org